



APIB Hail resistance No. 23397

Owner

Fundermax GmbH
Klagenfurterstr. 87
9300 St. Veit/Glan
Austria

Producer

Fundermax GmbH
9300 St. Veit/Glan
Austria

Group 133 - Façade - Plastic panels
Product Max. compact exterior F, 6 mm

Description

Balcony and façade Panels.
High-pressure laminate (type EDF and type EGF) with external weather protection made of toughened acrylic-polyurethane resins.
Thickness = 6 mm.
Surface finishes: NT, NH, NG, NM.
This approval certificate applies to all available colours. The product was tested with open joints.

Documents

IBS- Institut für Brandschutztechnik und Sicherheitsforschung Gesellschaft m.b.H.:
'132_1005_001' (27. Februar 2012), '318111405-1' (30. Januar 2019)

Test Regulations

11 ABIP plastic panels Version 1.04 dated 1 July 2015

Classification

Hail impact resistance - appearance HW 4*
Hail impact resistance - functionality HW 4*

Remarks

* This classification applies to new materials. Hail impact resistance can reduce in a few years as a result of natural weathering

Validity 31.12.2024
Date of issue 17.04.2019
Replaces classification of 06.08.2013

Association of Public Insurance Companies for Buildings

Martin Jordi

Eveline Augsburg

The functionality is the minimum hail resistance of the component functions:

Translucence	HW --	Mechanical	HW --
Light shielding	HW --	Water tightness	HW 4*